

Rumours Café Licence Application

Lincolnshire Fire and Rescue Conditions to be included in Licence:

The following generic fire precautions should become conditions of the above licence.

Fire Appliance Access

The number of tables, chairs and associated furniture should not exceed those applied for and their position must not obstruct fire appliance access to the premises, or any other premises.

Means of Escape

Any tables, chairs and associated furniture, which are sited outside the premises, must not obstruct the exit doors or exit routes from the premises, or any other premises.

Umbrellas and outside gas burners

If canopies/umbrellas and/or outside gas/electric burners/heaters are to be provided in the vicinity of the seating area, a suitable and sufficient fire risk assessment must be carried out with regard to their positioning prior to use. Any canopies/umbrellas provided should also be appropriately flame retardant where this is identified as necessary by the fire risk assessment.

Fire Risk Assessment

The responsible person at the premises must ensure that the existing fire risk assessment for the premises is updated as necessary in accordance with the Regulatory Reform (Fire Safety) Order 2005 prior to the siting of any outside furniture.

This page is intentionally left blank